



**BOARD OF COUNTY
COMMISSIONERS**

WWW.BAYCOUNTYFL.GOV

840 WEST 11TH STREET
PANAMA CITY, FL 32401

COMMISSIONERS:

TOMMY HAMM
DISTRICT I

ROBERT CARROLL
DISTRICT II

WILLIAM T. DOZIER
DISTRICT III

DOUGLAS MOORE
DISTRICT IV

PHILIP "GRIFF" GRIFFITTS
DISTRICT V

ROBERT J. MAJKA
COUNTY MANAGER

PURCHASING DEPARTMENT

840 West 11th Street
Panama City, Florida 32401
Telephone: (850) 248-8270
Fax: (850) 248-8276

April 19, 2022

Prospective Respondents

**RE: Addendum #3 22-44 Bay County Sheriff's Office Generator
Replacement Project Re-Bid HMGP Project 4399-014-R**

Please accept this as Addendum No. 3 for the above referenced solicitation.

The following questions have been received. The County's answers follow in **bold**.

1. Existing 400amp transfer switch is feed directly from utility transformer without any type of disconnect means. To meet code, a service rated transfer switch or a main disconnect switch is required. Please advise? **Whatever code requires is what the County will expect from the contractor's design engineer.**
2. Existing utility transformer has two services, a 400amp service and 800amp service, is the generator required to back up both services? **The new generator will be required to back up both services.**
3. Is the expectation to enlarge the existing generator concrete pad and fencing? **Yes.**
4. What is the power shut down window allowance? Weekends? Overnight? **Weekends or overnight would be advisable.**
5. Is any brand of generator manufacture acceptable? **In this case, yes.**
6. Is any brand of ATS manufacture acceptable? **In this case, yes.**

All respondents shall acknowledge receipt of this addendum by signing and submitting, with their bid, the addendum acknowledgement form included in the Bid package.

Regards,
Shelly Taunton
Purchasing Administrator