



**BOARD OF COUNTY
COMMISSIONERS**

WWW.BAYCOUNTYFL.GOV

840 WEST 11TH STREET
PANAMA CITY, FL 32401

COMMISSIONERS:

TOMMY HAMM
DISTRICT I

ROBERT CARROLL
DISTRICT II

WILLIAM T. DOZIER
DISTRICT III

DOUGLAS MOORE
DISTRICT IV

PHILIP "GRIFF" GRIFFITTS
DISTRICT V

ROBERT J. MAJKA
COUNTY MANAGER

PURCHASING DEPARTMENT

840 West 11th Street
Panama City, Florida 32401
Telephone: (850) 248-8270
Fax: (850) 248-8276

April 28, 2022

Prospective Respondents

**RE: Addendum #5 22-44 Bay County Sheriff's Office Generator
Replacement Project Re-Bid HMGP Project 4399-014-R**

Please accept this as Addendum No. 5 for the above referenced solicitation.

For clarification, ITB 22-44 Bay County Sheriff's Office Generator Replacement Project Re-Bid is HMGP Project number **4399-014-R**

The following questions have been received. The County's answers follow in **bold**.

1. Can the County confirm total service size? **There are two services to the building, one 400 amp, and one 800 amp. The 400-amp service is currently serviced by the existing generator and transfer switch. The intent is to add the 800-amp service to the backup power.**
2. How much run time are you needing from the diesel fuel tank? **72 hours.**
3. Is the existing generator pad elevation acceptable for the new generator as well? Any issues with flood levels? **No, generator pad elevation must be constructed to meet 500-year flood elevation requirements as set forth in grant documents.**
4. Is a portable backup generator needed during service outages? **The County will provide a portable generator. The contractor will be required to wire in the portable generator when deemed necessary.**
5. Is a generator load bank test required at startup. If so, how many hours are required? **Whatever time frame is recommended by the manufacturer.**
6. Are there any provisions for price escalation, if any, between bid date and equipment release date? **No.**

7. In reviewing Addendum #4, I see the answer to question 1 states "48 hour" run time on the fuel tank. The revised Scope of Work states that a "72" hour run time is required. Please clarify. **72 hours is required.**

All respondents shall acknowledge receipt of this addendum by signing and submitting, with their bid, the addendum acknowledgement form included in the Bid package.

Regards,
Scott Nabers
Contract Administrator