



BOARD OF COUNTY
COMMISSIONERS

WWW.BAYCOUNTYFL.GOV

840 WEST 11TH STREET
PANAMA CITY, FL 32401

COMMISSIONERS:

TOMMY HAMM
DISTRICT I

ROBERT CARROLL
DISTRICT II

WILLIAM T. DOZIER
DISTRICT III

DOUGLAS MOORE
DISTRICT IV

CLAIR PEASE
DISTRICT V

ROBERT J. MAJKA
COUNTY MANAGER

PURCHASING DEPARTMENT

840 West 11th Street
Panama City, Florida 32401
Telephone: (850) 248-8270
Fax: (850) 248-8276

March 27, 2024

Prospective Respondents

RE: Addendum #2 24-33 Sulfuric Acid for the Water Treatment Plant

Please accept this as Addendum No. 2 for the above referenced solicitation.

The following questions have been received. The County's answers follow in **bold**.

What percent sulfuric acid you are asking for? **The sulfuric acid delivered under the agreement shall be 92.8 to 96.8 percent by weight sulfuric acid (H₂SO₄).**

What is the volume of the acid? **Acid tank is 5500 gallons.**

How fast will they be going through the amount available? **Sulfuric will be approximately 9-12 loads per year.**

How will they be moving it from truck to onsite tank? **Truck will need air to transfer to holding tank.**

Page 8 of 41 of the bid document reads, "Hydrated Lime' under the Material Specifications. **The Material Specifications on page 8 of 41 of the solicitation shall hereby read " Bidder shall comply with Exhibit 1 Sulfuric Acid Bid Specifications"**

All respondents shall acknowledge receipt of this addendum by signing and submitting, with their bid, the addendum acknowledgement form included in the Bid package.

Regards,

Scott Nabers
Contract Administrator