



August 5, 2024

Prospective Respondents

**RE: Addendum #3 24-51 Harders Walking Path Re-Surfacing Project**

Please accept this as Addendum No. 3 for the above referenced solicitation.

The following questions have been received. The County's answers follow in **bold**.

1. What exactly is this? I don't see any description for this. **It is a leveling course of asphalt at a spread rate of 75 lbs/sy**

LEVELING COURSE ✓  
(75 LBS/SY)

All respondents shall acknowledge receipt of this addendum by signing and submitting, with their bid, the addendum acknowledgement form included in the Bid package.

Regards,

Scott Nabers

Contract Administrator  
Bay County Purchasing Department  
(850) 248-8270  
[Purchasing@baycountyfl.gov](mailto:Purchasing@baycountyfl.gov)